



Washington Latin PCS (2nd Street Campus) - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Washington Latin PCS (2nd Street Campus)	WS-038-001	Cooler	1	In hallway across from room 105	High	Left	WF-012025-038001-07	6/13/2025	FT-FY25-012025-038001-A	<1	FT-FY25-012025-038001-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-002	Cooler	1	In hallway across from room 105	Low	Right	WF-012025-038002-07	6/13/2025	FT-FY25-012025-038002-A	<1	FT-FY25-012025-038002-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-003	Break Room	1	In break room 121			WF-012025-038003-07	6/13/2025	FT-FY25-012025-038003-A	<1	FT-FY25-012025-038003-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-006	Cooler	1	In hallway across from room 134	High	Left	WF-012025-038006-07	6/13/2025	FT-FY25-012025-038006-A	<1	FT-FY25-012025-038006-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-007	Bottle Filler	1	In hallway across from room 134	High	Left	WF-012025-038007-07	6/13/2025	FT-FY25-012025-038007-A	<1	FT-FY25-012025-038007-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-008	Cooler	1	In hallway across from room 134	Low	Right	WF-012025-038008-07	6/13/2025	FT-FY25-012025-038008-A	<1	FT-FY25-012025-038008-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-009	Cooler	Ground	In gymnasium	High	Left	WF-012025-038009-07	6/13/2025	FT-FY25-012025-038009-A	<1	FT-FY25-012025-038009-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-010	Bottle Filler	Ground	In gymnasium	High	Left	WF-012025-038010-07	6/13/2025	FT-FY25-012025-038010-A	<1	FT-FY25-012025-038010-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-011	Cooler	Ground	In gymnasium	Low	Right	WF-012025-038011-07	6/13/2025	FT-FY25-012025-038011-A	<1	FT-FY25-012025-038011-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-012	Cooler	2	In hallway across from room 234	High	Left	WF-012025-038012-07	6/13/2025	FT-FY25-012025-038012-A	<1	FT-FY25-012025-038012-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-013	Bottle Filler	2	In hallway across from room 234	High	Left	WF-012025-038013-07	6/13/2025	FT-FY25-012025-038013-A	<1	FT-FY25-012025-038013-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-014	Cooler	2	In hallway across from room 234	Low	Right	WF-012025-038014-07	6/13/2025	FT-FY25-012025-038014-A	<1	FT-FY25-012025-038014-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-015	Cooler	2	In hallway adjacent to room 227	High	Left	WF-012025-038015-07	6/13/2025	FT-FY25-012025-038015-A	<1	FT-FY25-012025-038015-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-016	Cooler	2	In hallway adjacent to room 227	Low	Right	WF-012025-038016-07	6/13/2025	FT-FY25-012025-038016-A	<1	FT-FY25-012025-038016-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-017	Cooler	1	In hallway adjacent to room 125	High	Left	WF-012025-038017-07	6/13/2025	FT-FY25-012025-038017-A	<1	FT-FY25-012025-038017-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-018	Cooler	1	In hallway adjacent to room 125	Low	Right	WF-012025-038018-07	6/13/2025	FT-FY25-012025-038018-A	<1	FT-FY25-012025-038018-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-019	Cooler	2	In hallway across from room 205	High	Left	WF-012025-038019-07	6/13/2025	FT-FY25-012025-038019-A	<1	FT-FY25-012025-038019-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-020	Bottle Filler	2	In hallway across from room 205	High	Left	WF-012025-038020-07	6/13/2025	FT-FY25-012025-038020-A	<1	FT-FY25-012025-038020-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-021	Cooler	2	In hallway across from room 205	Low	Right	WF-012025-038021-07	6/13/2025	FT-FY25-012025-038021-A	<1	FT-FY25-012025-038021-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-022	Cooler	Basement	In hallway adjacent to room 017	High	Left	WF-012025-038022-07	6/13/2025	FT-FY25-012025-038022-A	<1	FT-FY25-012025-038022-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-023	Bottle Filler	Basement	In hallway adjacent to room 017	High	Left	WF-012025-038023-07	6/13/2025	FT-FY25-012025-038023-A	<1	FT-FY25-012025-038023-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-024	Cooler	Basement	In hallway adjacent to room 017	Low	Right	WF-012025-038024-07	6/13/2025	FT-FY25-012025-038024-A	<1	FT-FY25-012025-038024-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-025	Cooler	Basement	In music room 021			WF-012025-038025-07	6/13/2025	FT-FY25-012025-038025-A	<1	FT-FY25-012025-038025-B	<1
Washington Latin PCS (2nd Street Campus)	WS-038-026	Health Suite	Basement	In health suite 023			WF-012025-038026-07	6/13/2025	FT-FY25-012025-038026-A	<1	FT-FY25-012025-038026-B	<1