



Washington Latin PCS (Cooper Campus) - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Washington Latin PCS [Cooper Campus]	WS-151-001	Health Suite	1	In health suite			WF-022025-151001-04	5/16/25	FT-FY25-022025-151001-A	<1	FT-FY25-022025-151001-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-002	Cooler	1	In hallway adjacent to women's restroom	High	Left	WF-022025-151002-04	5/16/25	FT-FY25-022025-151002-A	<1	FT-FY25-022025-151002-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-003	Cooler	1	In hallway adjacent to women's restroom	Low	Right	WF-022025-151003-04	5/16/25	FT-FY25-022025-151003-A	<1	FT-FY25-022025-151003-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-004	Food Prep Sink	1	In Kitchen		Left	WF-022025-151004-04	5/16/25	FT-FY25-022025-151004-A	<1	FT-FY25-022025-151004-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-005	Food Prep Sink	1	In kitchen		Right	WF-022025-151005-04	5/16/25	FT-FY25-022025-151005-A	<1	FT-FY25-022025-151005-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-006	Cooler	1	In gym	High	Left	WF-022025-151006-04	N/A	FT-FY25-022025-151006-A	Non-operational	FT-FY25-022025-151006-B	Non-operational
Washington Latin PCS [Cooper Campus]	WS-151-007	Cooler	1	In gym	Low	Right	WF-022025-151007-04	N/A	FT-FY25-022025-151007-A	Non-operational	FT-FY25-022025-151007-B	Non-operational
Washington Latin PCS [Cooper Campus]	WS-151-008	Classroom Faucet	1	In lobby behind security desk			WF-022025-151008-04	5/16/25	FT-FY25-022025-151008-A	<1	FT-FY25-022025-151008-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-009	Break Room	1	In break room		Left	WF-022025-151009-02	5/16/25	FT-FY25-022025-151009-A	<1	FT-FY25-022025-151009-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-010	Break Room	1	In break room		Right	WF-022025-151010-02	5/16/25	FT-FY25-022025-151010-A	<1	FT-FY25-022025-151010-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-011	Cooler	1	In hallway adjacent to custodial closet	High	Left	WF-022025-151011-02	5/16/25	FT-FY25-022025-151011-A	<1	FT-FY25-022025-151011-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-012	Cooler	1	In hallway adjacent to custodial closet	Low	Right	WF-022025-151012-02	5/16/25	FT-FY25-022025-151012-A	<1	FT-FY25-022025-151012-B	<1
Washington Latin PCS [Cooper Campus]	WS-151-013	Food Prep Sink	1	In kitchen		Right	WF-022025-151013-02	5/16/25	FT-FY25-022025-151013-A	<1	FT-FY25-022025-151013-B	<1